



344 - 7th Avenue NE
Calgary, AB T2E 0M9
W: (403) 233-7037 F: (403) 233-7036

June 7, 2012

British Columbia Utilities Commission
600, 900 Howe Street, Box 250
Vancouver, B.C V6Z 2N3

Attention: Ms. Alanna Gillis, Acting Commission Secretary

Dear Madam:

RE: BRITISH COLUMBIA HYDRO AND POWER AUTHORITY DAWSON CREEK/CHETWYND AREA
TRANSMISSION PROJECT, CERTIFICATE OF PUBLIC CONVENIENCE AND NECESSITY
APPLICATION PROJECT NO.3698640/ORDER G-132-11

INTERVENERS EVIDENCE TO BC HYDRO

Attached please find Interveners Evidence.

Sincerely,

A handwritten signature in blue ink, appearing to read 'J. Shand', is written over a horizontal dashed line.

Jamie Shand, President
Current Solutions Inc.

Attach.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35

Current Solutions Inc.
SUBMITTAL OF EVIDENCE
TO: BRITISH COLUMBIA HYDRO & POWER AUTHORITY
June 7, 2012
PROJECT NO: 3698640
CPCN – Dawson Creek/Chetwynd Area Transmission Project

Current Solutions Inc (“CSI”) specializes in power interconnections for large industrial customers across North America, with most of its focus and experience in British Columbia and Alberta, specifically for pipeline and oil and gas customers. Over the past ten years, CSI has worked with BCTC, BC Hydro and several industrial customers on at least 10 major interconnections that impact BC Hydro’s high voltage system. CSI has been involved with System Impact Studies throughout BC with several of these studies recently carried out in the Dawson Creek area. With our experience, CSI is knowledgeable about most aspects of System Impact Studies and can be considered a valuable resource in power interconnections to the grid.

Current Solutions Inc. completely supports the approval and immediate installation of the DCAT project (Project No: 3698640). This project should be simplified by approving it as “system reinforcement” required for the operation of the Bear Mountain Wind Farm IPP and the future load connection of a few industrial customers. CSI believes the need for DCAT was initiated by the Bear Mountain Wind Farm and supported by the future load growth from various new industrial customers in the area.

We suggest that Industrial customers do not need to be burdened with the commercial and regulatory conditions suggested by BC Hydro. While CSI believes the original need for the DCAT is driven by the Bear Mountain Wind Farm IPP, the absence of this DCAT system reinforcement is a major problem for the current and future system reliability in the area. The combined operation of the Bear Mountain Wind Farm, and the addition of new industrial load, has significantly reduced the ability for BC Hydro to provide the required standard of service to existing and future customers in the DCAT area.

The immediate installation of the transmission system reinforcement facilities for the DCAT project is essential for BC Hydro to provide a reliable standard of service to serve existing and future customers in Dawson Creek, especially under contingency (n-1) conditions. The proposed DCAT facilities are both beneficial to the grid and the local economy¹. DCAT provides an overall net good to society and any further schedule delay would be detrimental to society.

¹ Exhibit C18-1 & Exhibit C18-2 – City of Dawson Creek

36 **1.0 NEED FOR 230 kV DCAT FACILITIES**

37 CSI concurs with BC Hydro that the DCAT facilities are needed to accommodate new
38 industrial load on the system. CSI also submits that the DCAT facilities are clearly
39 required for the continued operation and potential expansion of the existing Bear
40 Mountain Wind Farm IPP (“BMW”).

41 The following items support the direction that BC Hydro’s need for the 230 kV DCAT
42 reinforcements were initially driven by the interconnection of the BMW IPP.

- 43 • Bear Mountain was the only wind farm IPP not connected initially at 230 kV. All
44 other wind farms on BC Hydro’s grid will be interconnected at 230 kV². *Why*
45 *would all other wind IPPs (some smaller than Bear Mountain) require 230 kV and*
46 *not Bear Mountain?*
- 47 • CSI has reviewed the System Impact Study referenced by BC Hydro in its
48 response to CSI’s IR No. 4.1.a³. This study was undertaken by BCTC for the
49 Bear Mountain Wind Farm IPP. The study when published was incomplete in
50 many areas. Several sections of this SIS report required follow-up studies to
51 determine the impact of the wind farm operation on the system. The SIS report
52 results are discussed in more detail below.

53 **1.1. System Impact Study (SIS)**

54 A SIS report generally provides Power Flow Modeling, Impact on the Bulk Transmission
55 System and Location of Connection or Tap point as described following.

56 **1.1.1. Power Flow Modeling**

57 Power flow modeling determines the impact on the transmission system from the
58 interconnection of the new load. This analysis is typically carried out through load flow
59 modeling under steady state (N-0) and contingency (N-1) conditions⁴.

60 The evidence in the published SIS⁵ states that on page 3:

61 *“The Bear Mountain WTG model, which is a user-defined model, is provided by*
62 *the manufacturer, ENERCON. BCTC has tested this model extensively and the*
63 *simulation results have revealed that it does not work properly for the subject*
64 *study. The Manufacturer has revised the WTG model several times unfortunately*
65 *without success. It has been observed that the root cause of the problem could*
66 *be the voltage regulator. In the interest of time and for this study purpose, the*
67 *voltage regulator is disabled as agreed by the IPP.”*

68 Also,

² Exhibit B-30, CSI_4_002_0a, pdf page 145, BC Hydro response to CSI IR 4.2.a

³ Exhibit B-30, CSI_4_001_0a, pdf page 143, BC Hydro response to CSI IR 4.1.a

⁴ Exhibit B-30, CSI_4_003_0a, pdf page 152, BC Hydro response to CSI IR 4.3.a

⁵ Exhibit B-30, CSI_4_001_0a, pdf page 143, BC Hydro response to CSI IR 4.1.a, Bear Mountain Wind Farm IPP Interconnection Impact Study, SPA 2007- 013M

69 “Detailed system operation planning study with actual data will be performed in
70 the later stage”

71 *Source: Bear Mountain Wind Farm IPP Interconnection Impact Study, SPA 2007-*
72 *013M, by British Columbia Transmission Corporation*

73 Therefore it is clear that the impact on the transmission system from the interconnection
74 of the new load could not be carried out for this Bear Mountain Wind Farm SIS report
75 because the model was not working properly. Normally BC Hydro (and previously
76 BCTC) published the load flow study results as one of the major outputs or deliverables
77 from the SIS report. With no model to be used for the flow analysis, it was clear that this
78 load flow analysis was not carried out in the published 2007 SIS report. For this reason
79 alone, the report is incomplete and required an “impact re-study” as stated on page 6 of
80 the SIS report⁵.

81 From the evidence submitted, CSI has not seen any studies or re-impact studies where
82 the load flow analysis was carried out and results documented in an SIS report.
83 Furthermore, per BC Hydro’s IR response⁶, BC Hydro states that “Dynamic switching
84 studies were not undertaken”. CSI submits that wind generation results in voltage
85 regulation issues as described by ABB below:

86 *“To a certain degree, voltage control problems caused by deficit of reactive power in*
87 *the grid can be, and is, remedied by installation of fixed or mechanically switched*
88 *shunt capacitors. This will not help on voltage fluctuations, however, caused by*
89 *varying output of wind generators. Regular voltage flicker is part of the picture, as*
90 *well, caused by such phenomena as turbulent wind impact and so-called tower*
91 *shadow effects. On top of this comes concerns for voltage collapses due to grid*
92 *faults, as well as for fast appearing overvoltages associated with sudden islanding*
93 *of wind power fed parts of distribution grids containing shunt capacitors for reactive*
94 *power support.”*

95 And

96 *“As can be expected, the severity of impact on power quality from wind power*
97 *operation is dependent on the strength, i.e. the fault level of the grid to which a wind*
98 *mill or indeed a whole wind farm is connected.*

99 *Source: ABB Power Systems AB, AC Power Division, “Voltage and power*
100 *quality control in wind power applications by means of dynamic*
101 *compensation”, by Rolf Grünbaum, www.abb.com*

102 ABB is stating that one way of increasing system fault levels at wind installations is to
103 increase the transmission voltage very close to the point of interconnection and to
104 provide a high voltage transmission path to large generators. To mitigate voltage control
105 problems caused by the normal operation of Bear Mountain Wind Generation, BC Hydro
106 is interconnecting Bear Mountain with the GMS generators via a 230 kV transmission
107 system.

⁶ Exhibit B-30, CSI_4_002_0c, pdf page 148, BC Hydro response to CSI IR 4.2.c

108 CSI questions why dynamic switching studies were not undertaken to evaluate the
109 voltage flicker impacts of the Bear Mountain Wind farm and similarly, why the load flow
110 studies were not carried out as part of the original SIS Report.

111 1.1.2. Impacts on the Bulk Transmission System

112 Impacts on the bulk transmission system determine what, if any, equipment is required
113 for the system to accommodate this new load. This recommendation is then taken as
114 the input for the Facility Study which in turn determines the design, cost and schedule to
115 build the new reinforcement facilities identified in the SIS.

116 On page 4 of the Bear Mountain Wind Farm IPP, SIS report 5, BC Hydro states:
117 *“Impacts to the bulk electric transmission system are not included.”* CSI wonders why
118 this was not analyzed, especially when the main purpose of the SIS is to actually
119 determine the impact on the system. On page 6 of that same report, it states *“Impact to*
120 *the bulk transmission system is not included in the assessment and will be covered in a*
121 *separate study”*. There is no evidence submitted from BC Hydro that a separate or
122 additional study was carried out.

123 Based on the technical issues discussed, CSI submits that as part of BC Hydro’s
124 technical due diligence, a 230 kV solution should have been modeled during the SIS
125 report but due to the previously mentioned issues, it was not. BC Hydro in the SIS report
126 recommended restudying this impact at a later date.

127 CSI believes that BC Hydro would not ignore the findings of its incomplete, preliminary
128 SIS report. It can therefore only be concluded (probably for the sake of time and
129 efficiency) that the results from the DCAT study or analysis was used in lieu of a
130 transmission system reimpact study for BMW to provide the above technical analysis not
131 performed in the aforementioned early SIS report. Therefore, in the absence of a
132 complete SIS for the BMW Power IPP, and as proper due diligence by BC Hydro, the
133 DCAT analysis for new 230 kV facilities provided the appropriate recommendation in lieu
134 of an updated SIS for BMW. With the technical recommendations presented earlier
135 concerning wind power and its impact on the system, CSI believes BC Hydro did the
136 correct technical recommendation to upgrade the infrastructure serving the Bear
137 Mountain Wind Farm IPP to 230 kV.

138 1.1.3. Location of Connection or Tap Point

139 This section will recommend the location for the suggested local tap or interconnection
140 point. The actual tap point is not material to DCAT and will not be discussed further. On
141 another note however, due to the constant referral to the need for future other studies
142 referred to in items 3-10 of the SIS report, the entire credibility and applicability of the
143 2007 SIS Report results is questionable.

144 1.2. Original System Impact Study Report was Incomplete

145 The initial SIS work done by BC Hydro as discussed in section 1.1 was preliminary and
146 incomplete. The initial SIS report carried out in 2007 required detailed follow up, which in
147 CSI’s respectful submission is what the DCAT study became; the detailed updated
148 version of the Bear Mountain SIS interconnection work.

149 BC Hydro submitted no other evidence to show that the requirements for an updated SIS
150 for the BMW Wind Farm IPP had been completed. BC Hydro provided evidence that the
151 initial SIS was carried out in the report SPA 2007-013M⁵ with no other supplementary
152 evidence of additional SIS follow up. Therefore, it is clear that the true impact of the
153 operation of the 120 MW BMW Farm IPP on the system was never determined.

154 As such, CSI respectfully submits that this study was incomplete and required further
155 detailed modeling and analysis. CSI believes that the DCAT system studies that followed
156 were in fact a follow up to the SIS Report. The DCAT study provided the detailed
157 analysis and impact restudy that was referred to in the initial April 2007 study conducted
158 by BCTC.


159

160 **2.0 NEED FOR GDAT AND NEW SYSTEM FACILITIES**

161 The updated load forecast submitted by BC Hydro in their March 23rd letter shows
162 significant load growth, increasing beyond 350 MW, starting in F2014⁷. The proposed
163 DCAT Alternative 1 submitted by BC Hydro indicates DCAT Alternative 1 will increase
164 the N-1 capacity in the region to 185 MW⁸.

165 **Figure 1: Load forecast of aggregated customer load in the DCAT study area for a**
166 **30 year period from fiscal year 2011 to 2041**

167 (Source: Exhibit B-6, IR Response No. 1.6.1 Dated: September 22, 2011)



⁷ Exhibit B-22, Supplemental Evidence, Section 3 - Load Forecast for the DCAT region

⁸ Exhibit B-6, pdf page 21, BC Hydro responses to BCOAPO IR 1.6.1

168 Therefore, the evidence submitted shows the proposed DCAT system Alternative 1
169 capacity increase to 185 MW will not provide capacity to serve the predicted load of
170 future customers with an estimated load of over 350 MW in F2014. Clearly, this shows a
171 need for an expanded, more robust, transmission system than what the DCAT project
172 proposes as shown as the “F2016 stage” or GDAT.


173 **2.1. Duplication of Facilities**

174 The submitted possible future transmission system configuration diagram⁹ by BC Hydro
175 shows the current 230 kV transmission system that provides support to accommodate
176 the addition of several new wind farm IPPs also included on the possible future
177 transmission system configuration.

178 The possible future transmission system configuration shown in Figure 2 also provides
179 generic bubbles for new load in the region as BC Hydro stated “The POI of other load
180 interconnections in the area are not confirmed at this time”¹⁰. This opens the possibility
181 of multiple connection points to the existing transmission and substation network.

182 **Figure 2: BC Hydro submitted future transmission system configuration diagram.**

183 (Source: Exhibit B-5, IR Response No. 1.18.3 Dated: September 15, 2011)



⁹ Exhibit B-30, BCUC_4_004_08_01, pdf page 32, BC Hydro response to BCUC IR 4.4.8.1

¹⁰ Exhibit B-30, BCUC_4_004_08_01, pdf page 31, BC Hydro response to BCUC IR 4.4.8.1

184 To date, CSI is unaware of any evidence submitted by BC Hydro that shows any plans
185 for transmission lines and any system substations to serve the other numerous industrial
186 oil and gas customer's that have submitted applications in the area. It seems
187 contradictory and short sighted for BC Hydro to claim that the need for DCAT is driven
188 entirely by industrial customer load but not have any system substation to serve the
189 generic industrial customer geographical loads noted in the "bubbles" on the submitted
190 drawings. Of note, the only substation in the DCAT proposal is right next to the Bear
191 Mountain Wind Farm, many kilometers from the load centre of the majority of the
192 proposed industrial load customers.

193 CSI submits that for DCAT (and in the future GDAT) to be properly planned and
194 designed to serve industrial load customers (not just wind farm IPPs) system substations
195 should be planned for efficient and effective interconnection and service. This is further
196 discussed below.

197 CSI believes the process and practices previously in place at BC Hydro and formerly
198 BCTC need to be changed to accommodate the services required for the Oil and Gas
199 customers. The existing model in BC has worked for services such as mines and other
200 single, isolated industrial customers.

201 CSI will quickly outline the interconnection process concerning design and ownership.

202 The current process in BC involves the industrial customer designing, building and
203 owning and operating its own transmission line and customer owned substation as
204 defined as part of the electric tariff. This was the case following the interconnection of
205 Louisiana Pacific (LP). LP was required to construct their own private substation
206 designated LAP as shown in the previous figure provided by BC Hydro¹¹. As a result,
207 the proposed DCAT project was unable to utilize the now private LAP substation and is
208 instead proposing to construct a new Sundance substation (SLS)¹². Reviewing the
209 provided map shows that this new SLS substation is very close to the existing private
210 LAP. This, in CSI's respectful submission, is a duplication of assets and not an efficient
211 transmission planning design for the net good of society.

212 One overall result of this current process is that multiple customers are tapping into the
213 same transmission line in different (albeit close) locations with their own private facilities
214 rather than utilizing a preplanned and well-designed system substation. The existing
215 process has allowed customers to be served via their own capital cost and risk but it has
216 resulted in the duplication of facilities as seen with LAP. The result of this process over
217 the years has not built up a public transmission infrastructure in BC for usage by any
218 other users aside from the initial customer.

219 The customer owned facility model creates what may be deemed as a random and
220 chaotic version of transmission system planning because the customer is in control of
221 the timing, design, routing and size of the facilities. The unknown timing and location of
222 the tap points and customer owned substations as shown in the "bubble" on the *possible*
223 *future transmission system configuration* provided in Figure 2 supports this statement.

¹¹ Exhibit B-1, pdf page 15, Chapter 1 - Introduction

224 It is difficult for BC Hydro to perform a coordinated overall transmission system planning
225 model since the customer controls the process and each customer will control their own
226 schedule with no central or overall planning concern for the benefit of the province or
227 rate payers. This point is shown as part of the DCAT study because after considerable
228 amount of work and planning by BC Hydro, the only reference to the customer owned
229 substations submitted in the planning interconnection drawing is a “bubble”.

230 In Alberta, the transmission system planning model is more appropriate for the Oil and
231 Gas Customers, where many customers (even competitors) require service in the same
232 area. The system builds a transmission line and substation to serve many customers.
233 Each project requires regulatory scope, need, cost and facility approval. The substation
234 can be either a system substation to serve many customers or a customer owned
235 substation to service a single customer. Once a substation or transmission line is built, it
236 is a public line and therefore allows access by any future user.

237 The Alberta process for transmission supply is somewhat similar to the BC Hydro
238 Distribution process where the Utility designs, owns and operates the line. It is built to
239 serve the initial customer but any future customers can have access. Similar to the BC
240 Hydro 25 kV projects, the initiating customer pays a capital contribution and the system
241 contributes capital funds based on the size of the contracted load.

242

243 **3.0 BC GOVERNMENT POLICY AND ENERGY PLAN**

244 The BC Government realizes the importance of growth in the energy sector in BC. In
245 the BC Energy Plan¹², the BC government has encouraged the development of the
246 energy reserves as a high priority.

247 The BC Energy Plan⁸, number 12, states the following:

248 *“Since its inception, BCTC has planned system upgrades and new transmission*
249 *projects in response to a customer’s request. Transmission projects, however,*
250 *require longer lead and construction times than generation or load build. The*
251 *experience of other jurisdictions with this type of planning approach is that*
252 *transmission capacity is often not in place when it is needed.*

253 *To prevent this situation from occurring in British Columbia, BCTC (now only BC*
254 *Hydro) will move beyond this contract driven approach to an approach that*
255 ***builds infrastructure in advance of need.** The BC Transmission Corporation*
256 *will study and propose, where appropriate, system upgrades or expansions*
257 *based, in part, on its own assessment of future market needs”.*

258 *Source: The BC Energy Plan, “Electricity Policies”,*
259 <http://www.energyplan.gov.bc.ca>

260 The need for service still drives the approval of each power supply project but BC Hydro
261 is encouraged, via the Energy Plan, to properly plan and build the facilities for future

¹² “The BC Energy Plan” Electricity Policies -

http://www.energyplan.gov.bc.ca/PDF/BC_Energy_Plan_Electricity.pdf

262 growth without a contract for every MW of service to justify the expansion of its
263 infrastructure.

264 It is difficult to size a facility perfectly for the demand. However, if the facility is too small,
265 it cannot serve, therefore by definition, all facilities should be oversized or have some
266 surplus. In the case of the DCAT facilities, it is clear that the proposed 230 kV facilities
267 do not provide adequate future surplus (Post 2016) without the addition of GDAT. Since
268 the 230 kV facilities are fairly robust, there is some surplus space available on the line to
269 accommodate near term future load. This is just good system planning. The surplus
270 capacity is available for future loads and per the Energy Plan should not have to be
271 contracted for.

272 Based on the BC governments Energy Plan, CSI recommends that no additional
273 commercial or regulatory commitments or terms be placed on any industrial customer's
274 connection to the grid in the Dawson Creek area or any other area in the province. The
275 customers will be committed to the terms and conditions signed off on their Electric
276 Service Agreement as approved by the existing tariffs.

277 CSI recommends that BC Hydro and BCUC approve the DCAT facilities without the
278 additional commercial and regulatory terms and conditions that BC Hydro has suggested
279 for this application. CSI respectfully submits that these terms and conditions are
280 discriminatory against a specific type of customer (oil and gas) and location (Dawson
281 Creek Area). It is the opinion of CSI that the new recommendations by BC Hydro are
282 against the Electric ACT but are, however, policy issues which the commission has
283 deemed outside the scope of this hearing and will not be further discussed in this
284 submittal.

285

286 **4.0 ALTERNATIVES FOR TRANSMISSION SERVICE**

287 BC Hydro needs to expand its transmission facilities throughout BC and specifically in
288 NE BC. The sooner this infrastructure gets built, the sooner the oil and gas companies
289 will grow the economy by creating jobs and delivering products to the markets.

290 To solve some of the infrastructure challenges facing BC Hydro and the industrial
291 customers in the area, some different methods of service could be looked at through
292 GDAT process. Discussed following are three alternative methods of service that could
293 be looked at to serve the future load.

294 **4.1. Status Quo**

295 4.1.1. Existing BC Hydro process where each industrial customer designs,
296 builds, owns and operates its own transmission lines and substations. The
297 capital funds for this work will be provided by the customer.

298 4.1.2. High voltage system planning is difficult because the customers control
299 the scope and timing of when the transmission lines are built. Duplication of
300 facilities results as does surplus unused capacity in customer owned
301 facilities.

302 4.1.3. The customer owns, operates and controls the transmission infrastructure,
303 mitigating rate increases for the transmission infrastructure.

304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341

4.2. New System Owned Facilities

- 4.2.1. A new process where BC Hydro designs a central transmission system to provide service for existing, proposed and future load in the area. The process would be similar to the existing BC Hydro 25 kV process where BC Hydro designs, owns and operates the facilities with capital contributions paid by the customer, depending on contracted load.
- 4.2.2. Due to the complexity and magnitude of the need for new facilities, as well as the tight timing required, it is probable that the BC government would need to give BC Hydro direction for the scope and timing of this service. It would likely involve an expanded version of the GDAT proposal with a 230 kV loop and substations to serve the customer load.
- 4.2.3. Funding could be provided as a special directive or infrastructure initiative by the BC Government so as to not increase rates to other customers. The funds have been prepaid by the Oil and Gas companies already as part of the \$6 billion in land lease funds. Additional funds could be requested by the government or BC Hydro, mitigating the rate increases for the T infrastructure. The key is to preplan and build in an organized manner with BC Hydro owned system lines and substations to serve a multitude of customers.
- 4.2.4. BC Hydro owns, operates and controls the transmission infrastructure. All existing and future customers would have access to the facilities.

4.3. Approval of an Industrial System Designation (ISD) for the Dawson Creek Industrial customers

- 4.3.1. An independent entity could build and own a 230 kV transmission loop and several gas fired efficient generators (combined cycle or cogeneration) so that both transmission service and generation would be provided. The BC Hydro grid would serve only as a backup service for reliability and system stability.
- 4.3.2. All generation and transmission costs of service would be accumulated privately and paid via a long term tariff to the ISD owner, independent of the BC Hydro rate schedules.
- 4.3.3. The ISD owner owns, operates and controls the transmission infrastructure, mitigating rate increases for both generation and transmission.
- 4.3.4. The BC government may have to change its policy and environmental emission charges to allow “clean” gas generation in BC, rather than just “green” power.
- 4.3.5. Onsite generation would provide voltage support to the BC Hydro grid and also back up power or surplus power to be supplied to the BC Hydro grid.

342 **5.0 SUMMARY**

343 CSI strongly supports the need for immediate installation of the proposed DCAT facilities.

344 CSI believes that DCAT is required immediately to provide system support to the Bear
345 Mountain Wind Farm IPP that has already been built.

346 Currently there are existing customers in the Dawson Creek who are served via an
347 interruptible service. This interruptible service is in contrast to other customers in BC who
348 are paying the same rate or tariff that enjoy a firm standard of electric service. Furthermore,
349 due to the current system constraints, BC Hydro is unable to serve new customers in the
350 Dawson Creek area, despite its obligation to serve.

351 The regulatory proceedings for DCAT can be considered precedent setting for the much
352 larger scope of work in the upcoming GDAT facilities.

353 BC Hydro is indeed governed by the electric tariff¹³ but it is directed by policy. The BC
354 Energy Plan developed provincial goals to attract oil and gas development¹⁴. Directionally,
355 the BC Government has recommended development of infrastructure to serve future
356 development of energy reserves. CSI respectfully submits that BC Hydro should follow this
357 direction and not impose new commercial terms and conditions on the Oil and Gas
358 Customers.

359 Careful and robust planning is required now for GDAT. This planning should include
360 transmission lines and substations to service all customers and not just IPPs.

361 BC Hydro and the BCUC need to ensure consistent treatment with a fair process and policy
362 for all customers in BC, not discriminated by type of industry, location, load or ownership.

363 In fairness to BC Hydro and the BCUC, there has been a significant change in the power
364 needs in BC over the past few years with the development of the shale gas reserves. The
365 oil and gas customers require many power supply services in a short time frame in
366 concentrated areas. The quantity of facilities and timing required for these services resulted
367 in a significant challenge to BC Hydro. As such, the existing BC Hydro interconnection and
368 regulatory processes were not equipped or appropriate for this new wave of services.

369 BC Hydro, BCUC and the BC Government should reexamine the processes and procedures
370 to accommodate this new load and develop the energy resources for the province of BC.
371 BC Hydro has an obligation to serve its customers, however if the process is too slow, the
372 service becomes not a viable alternative for today's oil and gas customers.

373 It is important for the good of the province (government, power rate payers, and industrial
374 customers, other stakeholders) to design and build a robust, efficient and effective
375 transmission power infrastructure. These facilities would allow access for all customers. It
376 would provide future expansion, minimize line losses, minimize duplication of facilities and

¹³ Exhibit B-30, CSI_4_005_0c, pdf page 163, BC Hydro response to CSI IR 4.5.c

¹⁴ BC Energy plan – Oil and Gas Background, 2007EMPR0008-000178,
http://www.energyplan.gov.bc.ca/PDF/2007EMPR0008_000178_Attachment3.pdf

377 also optimize the usage of the surplus or stranded assets such as customer owned
378 transmission lines and substations.

379 CSI believes that the first step in this process is the immediate installation of DCAT,
380 followed in parallel with proper planning for the future GDAT facilities with regulatory
381 support and direction for BC Hydro from the BCUC and the BC government.